

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0026:304 Page 1 of 1

CATEGORY: Ionization Smoke Detectors

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Model 912I ionization type, analog/addressable smoke detectors. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Units are also suitable for installation in high attitudes up to 9000 ft.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as smoke detectors for use with Models M612/912, 4B or 6B base (CSFM Listing No. 7300-1493:181) and separately listed compatible fire alarm control units.

XLf: 7271-1532:101

NOTE: Formerly 7271-1493:179

*Rev. 06-06-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager